



701½ West First Street
Defiance, OH 43512
Phone 419-782-6211
Fax 419-782-8722
architects@beilharzinc.com

June 8, 2011

HOLY CROSS CATHOLIC SCHOOL
Chapel Addition and Interior Alterations
Defiance, Ohio

A8-4241

ADDENDUM NO. 1

This Addendum becomes a part of the Contract Documents and modifies them only to the extent herein set forth. Each prime bidder is responsible for distribution of information conveyed by this Addendum to its subbidders and suppliers.

ITEM NO. 1: Section 04 2000 – Unit Masonry

Paragraph 2.02: Face brick shall be Belden Homestead Red, modular size.

ITEM NO. 2: Sheet SF101 – Foundation Plan and Details

Foundation Plan:

1. 14 inch wide foundation walls shall have 12 x 30 inch footings with 4 #5 bars continuous and #5 bars transverse at 24 inches o.c.
2. 18 inch wide foundation walls shall have 12 x 36 inch footings with 5 #5 bars continuous and #5 bars transverse at 24 inches o.c.
3. Section reference through exterior sign foundation shall be 12/A-303 in lieu of 14/SF101.

Foundation Detail 5: Foundation wall width shall be 1'-2" in lieu of 1'-4".

Foundation Detail 13: Foundation wall width shall be 1'-0".

ITEM NO. 3: Sheet A-201 – Exterior Elevations

North Sign Elevation 7: Section reference shall be 12/A-303 in lieu of 2/A-301.

END OF ADDENDUM