



701½ West First Street  
Defiance, OH 43512  
Phone 419-782-6211  
Fax 419-782-8722  
architects@beilharzinc.com

April 28, 2010

**KALIDA LOCAL SCHOOLS  
ST. MICHAELS ELEMENTARY  
Alterations  
Kalida, Ohio**

B0-4300

### **ADDENDUM NO. 2**

This Addendum becomes a part of the Contract Documents and modifies them only to the extent herein set forth. Each prime bidder is responsible for distribution of information conveyed by this Addendum to its subbidders and suppliers.

#### **ITEM NO. 1: Section 07 2216 – Roof Insulation**

Provide tapered insulation sloped at ¼ inch per foot for all roof areas. Prior to shop drawing preparation, probe existing roof assembly to determine elevations of deck and verify that minimum ¼ inch per foot slope will be provided at the surface of the completed roofing assembly. Indicate deck and surface elevations on shop drawings.

END OF ADDENDUM